

Location : NM1 (Tai Kwong Secondary School Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Calculated Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
3-Aug-10	11:00	64.8	67.0	62.5	64.2	55.9	70	N
9-Aug-10	11:05	65.0	67.5	63.0	64.2	57.3	70	N
20-Aug-10	11:00	64.9	67.5	63.5	64.2	56.6	70	N
26-Aug-10	10:55	66.4	68.5	63.5	64.2	62.4	70	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Calculated Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
3-Aug-10	13:00	66.6	69.5	63.5	68.1	-	75	N
9-Aug-10	10:10	68.9	70.5	64.5	68.1	61.2	75	N
20-Aug-10	13:00	67.5	69.5	64.5	68.1	-	75	N
26-Aug-10	16:12	68.5	70.5	65.0	68.1	57.9	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Calculated Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
3-Aug-10	14:00	64.5	66.5	63.0	64.8	-	70	N
9-Aug-10	14:20	64.5	66.0	63.0	64.8	-	70	N
20-Aug-10	11:30	65.3	67.0	63.0	64.8	55.7	70	N
26-Aug-10	14:55	64.0	66.0	62.5	64.8	-	70	N

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Calculated Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
3-Aug-10	11:30	65.7	68.0	63.0	67.4	-	75	N
9-Aug-10	14:00	67.5	70.5	64.5	67.4	51.1	75	N
20-Aug-10	13:30	65.7	68.0	63.5	67.4	-	75	N
26-Aug-10	14:00	65.7	67.5	63.0	67.4	-	75	N

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Calculated Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
3-Aug-10	19:00	63.7	65.5	62.0	65.2	-	75	N
9-Aug-10	13:30	63.9	65.5	62.5	65.2	-	75	N
20-Aug-10	14:30	64.6	66.5	63.0	65.2	-	75	N
26-Aug-10	15:35	63.5	65.0	59.0	65.2	-	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Calculated Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
3-Aug-10	13:15	63.5	64.5	62.0	64.5	-	70	N
9-Aug-10	13:05	65.3	66.0	64.0	64.5	57.6	70	N
20-Aug-10	14:05	63.7	65.0	62.5	64.5	-	70	N
26-Aug-10	11:40	64.2	65.5	60.5	64.5	-	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Calculated Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
3-Aug-10	9:55	58.5	60.0	56.0	61.5	-	75	N
9-Aug-10	10:15	59.8	61.0	57.5	61.5	-	75	N
20-Aug-10	9:50	58.8	60.0	57.0	61.5	-	75	N
26-Aug-10	9:45	59.0	60.0	56.5	61.5	-	75	N

Remarks  
\* +3dB(A) Façade effect correction included  
\*\* Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level