Location: NM1 (Tai Kwong Secondary School Rooftop - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Meas	ured Noise Le	vel for 30-min,	dB(A)	Baseline Noise	Calculated Construction	Limit Level,	Exceedance
Date	Start Time	Leq	L10	L90	Level, dB(A)	Noise Level, dB(A) **	dB(A)	(Y/N)
5-Oct-10	10:05	64.8	67.2	62.6	64.2	55.9	70	N

Location: NM2 (38 Ha Wun Yiu G/F - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Measured Noise Level for 30-min, dB(A)				Baseline Noise	Calculated Construction	Limit Level,	Exceedance
Date	Start Time	Leq*	L10*	L90*	Level, dB(A)*	Noise Level, dB(A) **	dB(A)	(Y/N)
5-Oct-10	13:50	67.2	71.3	63.3	68.1	-	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Measured Noise Level for 30-min, dB(A)				Baseline Noise	Calculated Construction	Limit Level,	Exceedance
Date	Start Time	Leq	L10	L90	Level, dB(A)	Noise Level, dB(A) **	dB(A)	(Y/N)
5-Oct-10	14:35	64.6	67.2	62.4	64.8	-	70	N

Location: NM4 (Uptown Plaza Block 4 Rooftop - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Measured Noise Level for 30-min, dB(A)				Baseline Noise	Calculated Construction	Limit Level,	Exceedance
Date	Start Time	Leq	L10	L90	Level, dB(A)	Noise Level, dB(A) **	dB(A)	(Y/N)
5-Oct-10	11:00	67.5	69.4	63.8	67.4	51.1	75	N

Location: NM5 (The Paragon Clubhouse Rooftop - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Measured Noise Level for 30-min, dB(A)				Baseline Noise	Calculated Construction	Limit Level,	Exceedance
Date	Start Time	Leq	L10	L90	Level, dB(A)	Noise Level, dB(A) **	dB(A)	(Y/N)
5-Oct-10	10:50	65.3	67.0	61.0	65.2	48.9	75	N

Location: NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field) Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

ſ		Measured Noise Level for 30-min, dB(A)				Baseline Noise	Calculated Construction	Limit Level,	Exceedance
	Date	Start Time	Leq*	L10*	L90*	Level, dB(A)*	Noise Level, dB(A) **	dB(A)	(Y/N)
ı	5-Oct-10	13:40	66.2	68.0	62.5	64.5	61.3	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Measured Noise Level for 30-min, dB(A)				Baseline Noise	Calculated Construction	Limit Level,	Exceedance
Date	Start Time	Leq	L10	L90	Level, dB(A)	Noise Level, dB(A) **	dB(A)	(Y/N)
5-Oct-10	9:50	61.8	63.5	58.5	61.5	50.0	75	N

## Remarks

+3dB(A) Façade effect correction included

<sup>\*\*</sup> Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level