

Location : NM1 (Tai Kwong Secondary School Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Calculated Construction Noise	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
2-Nov-10	10:49	64.1	66.0	62.0	64.2	-	70	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Calculated Construction Noise	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
2-Nov-10	11:30	67.7	69.0	63.5	68.1	-	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Calculated Construction Noise	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
2-Nov-10	13:30	63.5	65.0	61.5	64.8	-	70	N

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Calculated Construction Noise	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
2-Nov-10	13:10	65.7	68.0	63.0	67.4	-	75	N

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Calculated Construction Noise	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
2-Nov-10	14:10	62.0	63.5	59.0	65.2	-	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Calculated Construction Noise	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
2-Nov-10	10:30	64.0	65.5	62.5	64.5	-	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Calculated Construction Noise	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
2-Nov-10	9:49	58.0	60.0	56.0	61.5	-	75	N

Remarks

\* +3dB(A) Façade effect correction included

\*\* Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level