

Location : NM1 (Tai Kwong Secondary School Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-May-11	11:03	67.1	68.7	63.0	64.2	64.0	70	N
12-May-11	13:44	66.1	67.5	63.0	64.2	61.6	70	N
18-May-11	9:06	66.7	68.0	63.0	64.2	63.1	70	N
24-May-11	10:46	67.6	68.8	65.4	64.2	64.9	70	N
30-May-11	9:48	66.7	68.5	63.5	64.2	63.1	70	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
6-May-11	14:13	65.8	67.0	62.5	68.1	65.8	75	N
12-May-11	10:14	67.5	63.5	65.0	68.1	67.5	75	N
18-May-11	11:27	67.4	69.5	65.5	68.1	67.4	75	N
24-May-11	13:26	68.7	70.3	65.8	68.1	59.8	75	N
30-May-11	10:50	68.5	71.0	64.5	68.1	57.9	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-May-11	13:19	64.3	66.0	62.1	64.8	64.3	70	N
12-May-11	11:30	65.4	67.0	62.5	64.8	56.5	70	N
18-May-11	13:00	64.7	66.5	62.0	64.8	64.7	70	N
24-May-11	11:29	65.8	67.4	63.3	64.8	58.9	70	N
30-May-11	13:00	65.8	67.3	63.8	64.8	58.9	70	N

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-May-11	15:44	66.3	67.9	62.8	67.4	66.3	75	N
12-May-11	14:30	66.8	69.5	63.0	67.4	66.8	75	N
18-May-11	14:39	67.2	69.0	65.0	64.8	63.5	75	N
24-May-11	11:03	66.2	67.0	64.5	67.4	66.2	75	N
30-May-11	13:17	66.2	68.0	63.0	67.4	66.2	75	N

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-May-11	13:50	65.1	66.0	61.5	65.2	65.1	75	N
12-May-11	11:10	63.8	65.0	61.5	65.2	63.8	75	N
18-May-11	10:39	64.1	65.5	62.0	64.8	64.1	75	N
24-May-11	14:17	66.4	68.2	63.6	65.2	60.2	75	N
30-May-11	14:03	64.2	67.0	62.0	65.2	64.2	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
6-May-11	14:56	65.0	66.2	62.6	64.5	55.4	70	N
12-May-11	10:28	65.0	66.5	64.0	64.5	55.4	70	N
18-May-11	13:53	64.7	66.0	61.5	64.8	64.7	70	N
24-May-11	13:13	65.3	66.5	63.5	64.5	57.6	70	N
30-May-11	11:12	67.2	69.0	64.0	64.5	63.9	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-May-11	10:15	62.3	64.0	59.5	61.5	54.6	75	N
12-May-11	13:13	58.8	60.0	56.5	64.8	58.8	75	N
18-May-11	9:48	63.9	65.0	61.5	61.5	60.2	75	N
24-May-11	10:08	62.4	64.0	60.5	61.5	55.1	75	N
30-May-11	10:27	62.8	64.5	59.0	61.5	56.9	75	N

Remarks

* +3dB(A) Façade effect correction included

** Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level.

If Measured noise level < Baseline noise level, Corrected noise level = Measured noise level