

Location : NM1 (Tai Kwong Secondary School Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A) <sup>#</sup>	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
4-Jul-11	11:07	66.2	67.5	64.0	64.2	61.9	70	N
15-Jul-11	15:54	63.7	65.0	62.0	64.2	63.7	70	N
21-Jul-11	9:49	67.4	68.0	65.5	64.2	64.6	70	N
27-Jul-11	11:04	64.5	66.5	60.5	64.2	52.7	70	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
4-Jul-11	11:26	68.3	69.5	66.0	68.1	54.8	75	N
15-Jul-11	10:50	67.1	69.0	64.5	68.1	67.1	75	N
21-Jul-11	11:24	69.3	71.0	66.5	68.1	63.1	75	N
27-Jul-11	14:10	67.7	69.5	65.0	68.1	67.7	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A) <sup>#</sup>	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
4-Jul-11	13:09	67.2	69.0	65.0	64.8	63.5	70	N
15-Jul-11	13:20	64.1	66.0	62.5	64.8	64.1	70	N
21-Jul-11	13:11	67.7	69.5	66.0	64.8	64.6	70	N
27-Jul-11	13:20	63.2	64.5	61.5	64.8	63.2	70	N

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
4-Jul-11	13:00	64.8	66.5	62.0	67.4	64.8	75	N
15-Jul-11	13:05	65.5	67.0	63.0	67.4	65.5	75	N
21-Jul-11	13:02	68.2	72.0	66.0	67.4	60.5	75	N
27-Jul-11	10:35	67.0	69.0	62.0	67.4	67.0	75	N

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
4-Jul-11	10:16	64.3	66.5	62.0	65.2	64.3	75	N
15-Jul-11	14:00	60.1	61.5	57.5	65.2	60.1	75	N
21-Jul-11	11:04	67.7	70.5	65.5	65.2	64.1	75	N
27-Jul-11	10:10	63.0	64.5	60.5	65.2	63.0	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A) <sup>#</sup>	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
4-Jul-11	14:01	66.1	68.0	64.5	64.5	61.0	70	N
15-Jul-11	11:34	66.5	67.5	64.5	64.5	62.2	70	N
21-Jul-11	14:02	68.7	71.5	66.0	64.5	66.6	70	N
27-Jul-11	13:40	64.8	65.5	63.0	64.5	53.0	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
4-Jul-11	9:50	63.3	65.5	60.5	61.5	58.6	75	N
15-Jul-11	15:26	58.8	60.5	56.5	61.5	58.8	75	N
21-Jul-11	10:06	68.2	71.5	66.0	61.5	67.2	75	N
27-Jul-11	9:38	59.5	61.0	57.0	61.5	59.5	75	N

Remarks

\* +3dB(A) Façade effect correction included

# - Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.

\*\* Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level.

If Measured noise level < Baseline noise level, Corrected noise level = Measured noise level