Location: NM1 (Tai Kwong Secondary School Rooftop - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Measured Noise Level for 30-min, dB(A)				Baseline Noise	Corrected Construction	Limit Level,	Exceedance
Date	Start Time	Leq	L10	L90	Level, dB(A)	Noise Level, dB(A) **	dB(A) [#]	(Y/N)
21-Jul-11	9:49	67.4	68.0	65.5	64.2	64.6	70	N

Location: NM2 (38 Ha Wun Yiu G/F - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Measured Noise Level for 30-min, dB(A)				Baseline Noise	Corrected Construction	Limit Level,	Exceedance
Date	Start Time	Leq*	L10*	L90*	Level, dB(A)*	Noise Level, dB(A) **	dB(A)	(Y/N)
21-Jul-11	11:24	69.3	71.0	66.5	68.1	63.1	75	N

Location: NM3 (Wong Shiu Chi Middle School Rooftop - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Measured Noise Level for 30-min, dB(A)				Baseline Noise	Corrected Construction	Limit Level,	Exceedance
Date	Start Time	Leq	L10	L90	Level, dB(A)	Noise Level, dB(A) **	dB(A) [#]	(Y/N)
21-Jul-11	13:11	67.7	69.5	66.0	64.8	64.6	70	N

Location: NM4 (Uptown Plaza Block 4 Rooftop - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Measured Noise Level for 30-min, dB(A)				Baseline Noise	Corrected Construction	Limit Level,	Exceedance
Date	Start Time	Leq	L10	L90	Level, dB(A)	Noise Level, dB(A) **	dB(A)	(Y/N)
21-Jul-11	13:02	68.2	72.0	66.0	67.4	60.5	75	N

Location: NM5 (The Paragon Clubhouse Rooftop - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Measured Noise Level for 30-min, dB(A)				Baseline Noise	Corrected Construction	Limit Level,	Exceedance
Date	Start Time	Leq	L10	L90	Level, dB(A)	Noise Level, dB(A) **	dB(A)	(Y/N)
21-Jul-11	11:04	67.7	70.5	65.5	65.2	64.1	75	N

Location: NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field) Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Measured Noise Level for 30-min, dB(A)				Baseline Noise	Corrected Construction	Limit Level,	Exceedance
Date	Start Time	Leq*	L10*	L90*	Level, dB(A)*	Noise Level, dB(A) **	dB(A) [#]	(Y/N)
21-Jul-11	14:02	68.7	71.5	66.0	64.5	66.6	70	N

Location: NM7 (Riverain Bayside Switch Room Rooftop - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Measured Noise Level for 30-min, dB(A)				Baseline Noise	Corrected Construction	Limit Level,	Exceedance
Date	Start Time	Leq	L10	L90	Level, dB(A)	Noise Level, dB(A) **	dB(A)	(Y/N)
21-Jul-11	10:06	68.2	71.5	66.0	61.5	67.2	75	N

Remarks

* +3dB(A) Façade effect correction included

- Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.

** Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level.

If Measured noise level < Baseline noise level, Corrected noise level = Measured noise level