

Location : NM1A (168 Shek Kwu Lung Village G/F- Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-Sep-11	11:00	62.7	64.0	55.5	64.2	62.7	75	N
12-Sep-11	13:42	60.9	62.5	58.5	64.2	60.9	75	N
23-Sep-11	10:21	63.5	64.5	60.0	64.2	63.5	75	N
30-Sep-11	10:17	62.0	63.3	58.0	64.2	62.0	75	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
6-Sep-11	10:35	67.5	69.0	66.0	68.1	67.5	75	N
12-Sep-11	14:59	68.4	70.5	66.0	68.1	56.6	75	N
23-Sep-11	10:10	69.2	72.5	67.0	68.1	62.7	75	N
30-Sep-11	11:37	67.3	68.5	60.5	68.1	67.3	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-Sep-11	13:33	63.6	64.5	60.5	64.8	63.6	70	N
12-Sep-11	16:15	64.7	66.0	62.5	64.8	64.7	70	N
23-Sep-11	14:50	65.8	68.0	62.5	64.8	58.9	70	N
30-Sep-11	11:10	63.2	64.5	59.5	64.8	63.2	70	N

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-Sep-11	13:15	65.5	67.0	61.5	67.4	65.5	75	N
12-Sep-11	15:40	65.6	67.5	63.0	67.4	65.6	75	N
23-Sep-11	14:30	67.9	69.5	64.0	67.4	58.3	75	N
30-Sep-11	13:01	64.6	66.0	60.0	67.4	64.6	75	N

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-Sep-11	14:19	63.2	64.5	61.5	65.2	63.2	75	N
12-Sep-11	14:18	66.2	67.5	64.0	65.2	59.3	75	N
23-Sep-11	11:10	63.6	65.0	60.0	65.2	63.6	75	N
30-Sep-11	10:45	62.4	64.0	60.5	65.2	62.4	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
6-Sep-11	11:28	64.0	65.5	62.5	64.5	64.0	70	N
12-Sep-11	10:58	65.3	67.0	62.0	64.5	57.6	70	N
23-Sep-11	11:00	64.2	65.5	62.5	64.5	64.2	70	N
30-Sep-11	13:15	62.3	63.5	61.0	64.5	62.3	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-Sep-11	9:49	57.9	59.0	55.0	61.5	57.9	75	N
12-Sep-11	10:14	62.1	63.5	59.5	61.5	53.2	75	N
23-Sep-11	9:25	60.0	61.0	57.0	61.5	60.0	75	N
30-Sep-11	9:42	58.5	59.5	57.0	61.5	58.5	75	N

Remarks

\* +3dB(A) Façade effect correction included

# - Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.

\*\* Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level.

If Measured noise level < Baseline noise level, Corrected noise level = Measured noise level