

Location : NM1A (168 Shek Kwu Lung Village G/F- Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

| Date | Measured Noise Level for 30-min, dB(A) | | | | Baseline Noise Level, dB(A) | Corrected Construction Noise Level, dB(A) ** | Limit Level, dB(A) | Exceedance (Y/N) |
|-----------|----------------------------------------|------|------|------|-----------------------------|----------------------------------------------|--------------------|------------------|
| | Start Time | Leq | L10 | L90 | | | | |
| 4-Oct-11 | 9:38 | 62.3 | 63.5 | 60.0 | 64.2 | 62.3 | 75 | N |
| 10-Oct-11 | 10:31 | 62.2 | 63.1 | 58.1 | 64.2 | 62.2 | 75 | N |
| 21-Oct-11 | 13:03 | 62.2 | 63.5 | 59.5 | 64.2 | 62.2 | 75 | N |
| 27-Oct-11 | 13:03 | 62.6 | 63.5 | 61.0 | 64.2 | 62.6 | 75 | N |

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

| Date | Measured Noise Level for 30-min, dB(A) | | | | Baseline Noise Level, dB(A)* | Corrected Construction Noise Level, dB(A) ** | Limit Level, dB(A) | Exceedance (Y/N) |
|-----------|----------------------------------------|------|------|------|------------------------------|----------------------------------------------|--------------------|------------------|
| | Start Time | Leq* | L10* | L90* | | | | |
| 4-Oct-11 | 11:00 | 66.2 | 67.5 | 64.0 | 68.1 | 66.2 | 75 | N |
| 10-Oct-11 | 11:20 | 67.9 | 70.0 | 65.0 | 68.1 | 67.9 | 75 | N |
| 21-Oct-11 | 10:20 | 66.0 | 67.5 | 63.5 | 68.1 | 66.0 | 75 | N |
| 27-Oct-11 | 9:50 | 67.4 | 68.5 | 65.0 | 68.1 | 67.4 | 75 | N |

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

| Date | Measured Noise Level for 30-min, dB(A) | | | | Baseline Noise Level, dB(A) | Corrected Construction Noise Level, dB(A) ** | Limit Level, dB(A)# | Exceedance (Y/N) |
|-----------|----------------------------------------|------|------|------|-----------------------------|----------------------------------------------|---------------------|------------------|
| | Start Time | Leq | L10 | L90 | | | | |
| 4-Oct-11 | 11:10 | 64.9 | 67.0 | 61.5 | 64.8 | 48.5 | 70 | N |
| 10-Oct-11 | 13:07 | 66.2 | 68.3 | 63.6 | 64.8 | 60.6 | 70 | N |
| 21-Oct-11 | 13:49 | 64.2 | 65.5 | 60.5 | 64.8 | 64.2 | 70 | N |
| 27-Oct-11 | 11:20 | 64.4 | 66.5 | 61.0 | 64.8 | 64.4 | 70 | N |

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

| Date | Measured Noise Level for 30-min, dB(A) | | | | Baseline Noise Level, dB(A) | Corrected Construction Noise Level, dB(A) ** | Limit Level, dB(A) | Exceedance (Y/N) |
|-----------|----------------------------------------|------|------|------|-----------------------------|----------------------------------------------|--------------------|------------------|
| | Start Time | Leq | L10 | L90 | | | | |
| 4-Oct-11 | 14:45 | 65.3 | 67.5 | 62.5 | 67.4 | 65.3 | 75 | N |
| 10-Oct-11 | 13:04 | 64.7 | 66.5 | 62.0 | 67.4 | 64.7 | 75 | N |
| 21-Oct-11 | 14:09 | 65.1 | 66.5 | 60.5 | 67.4 | 65.1 | 75 | N |
| 27-Oct-11 | 11:30 | 65.8 | 67.0 | 62.0 | 67.4 | 65.8 | 75 | N |

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

| Date | Measured Noise Level for 30-min, dB(A) | | | | Baseline Noise Level, dB(A) | Corrected Construction Noise Level, dB(A) ** | Limit Level, dB(A) | Exceedance (Y/N) |
|-----------|----------------------------------------|------|------|------|-----------------------------|----------------------------------------------|--------------------|------------------|
| | Start Time | Leq | L10 | L90 | | | | |
| 4-Oct-11 | 14:57 | 61.8 | 62.5 | 59.5 | 65.2 | 61.8 | 75 | N |
| 10-Oct-11 | 14:02 | 63.9 | 66.0 | 61.5 | 65.2 | 63.9 | 75 | N |
| 21-Oct-11 | 10:00 | 63.1 | 64.5 | 60.5 | 65.2 | 63.1 | 75 | N |
| 27-Oct-11 | 10:25 | 63.2 | 64.5 | 60.0 | 65.2 | 63.2 | 75 | N |

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

| Date | Measured Noise Level for 30-min, dB(A) | | | | Baseline Noise Level, dB(A)* | Corrected Construction Noise Level, dB(A) ** | Limit Level, dB(A)# | Exceedance (Y/N) |
|-----------|----------------------------------------|------|------|------|------------------------------|----------------------------------------------|---------------------|------------------|
| | Start Time | Leq* | L10* | L90* | | | | |
| 4-Oct-11 | 15:35 | 63.5 | 64.5 | 62.0 | 64.5 | 63.5 | 70 | N |
| 10-Oct-11 | 11:28 | 65.6 | 67.7 | 62.3 | 64.5 | 59.1 | 70 | N |
| 21-Oct-11 | 11:10 | 64.4 | 65.5 | 63.0 | 64.5 | 64.4 | 70 | N |
| 27-Oct-11 | 10:41 | 64.7 | 65.5 | 62.5 | 64.5 | 51.2 | 70 | N |

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

| Date | Measured Noise Level for 30-min, dB(A) | | | | Baseline Noise Level, dB(A) | Corrected Construction Noise Level, dB(A) ** | Limit Level, dB(A) | Exceedance (Y/N) |
|-----------|----------------------------------------|------|------|------|-----------------------------|----------------------------------------------|--------------------|------------------|
| | Start Time | Leq | L10 | L90 | | | | |
| 4-Oct-11 | 10:04 | 58.0 | 59.5 | 57.0 | 61.5 | 58.0 | 75 | N |
| 10-Oct-11 | 9:45 | 61.8 | 63.5 | 58.0 | 61.5 | 50.0 | 75 | N |
| 21-Oct-11 | 9:17 | 59.0 | 60.0 | 57.5 | 61.5 | 59.0 | 75 | N |
| 27-Oct-11 | 10:41 | 58.6 | 59.5 | 57.0 | 61.5 | 58.6 | 75 | N |

Remarks
* +3dB(A) Façade effect correction included
- Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.
** Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level.
If Measured noise level < Baseline noise level, Corrected noise level = Measured noise level