

Location : NM1A (168 Shek Kwu Lung Village G/F - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
10-Jul-12	10:30	60.8	62.4	57.6	64.2	60.8	75	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
10-Jul-12	14:16	67.9	69.3	65.8	68.1	67.9	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
10-Jul-12	15:45	65.5	67.2	63.6	64.8	57.2	70	N

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
10-Jul-12	14:59	66.8	68.2	63.9	67.4	66.8	75	N

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
10-Jul-12	13:32	65.8	68.0	63.2	65.2	56.9	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
10-Jul-12	11:18	62.7	64.4	60.1	64.5	62.7	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
10-Jul-12	16:31	61.3	63.0	59.1	61.5	61.3	75	N

Remarks
* +3dB(A) Façade effect correction included
- Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.
** Construction noise level is only calculated when Measured noise level (Leq) > Impact noise level.
If Measured noise level < Impact noise level, Corrected noise level = Measured noise level