

Location : NM1A (168 Shek Kwu Lung Village G/F - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
1-Nov-12	14:15	62.4	63.5	54.4	64.2	62.4	75	N
7-Nov-12	11:20	65.8	67.9	61.4	64.2	60.7	75	N
13-Nov-12	10:20	63.3	65.6	61.0	64.2	63.3	75	N
19-Nov-12	16:35	60.5	63.1	56.3	64.2	60.5	75	N
30-Nov-12	13:00	63.7	66.9	60.8	64.2	63.7	75	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
1-Nov-12	13:00	67.9	68.8	59.9	68.1	67.9	75	N
7-Nov-12	13:08	66.3	68.4	63.5	68.1	66.3	75	N
13-Nov-12	10:10	62.2	65.0	56.9	68.1	62.2	75	N
19-Nov-12	11:25	63.6	64.8	61.2	68.1	63.6	75	N
30-Nov-12	11:00	65.1	68.3	62.6	68.1	65.1	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
1-Nov-12	11:00	64.7	67.1	59.5	64.8	64.7	70	N
7-Nov-12	11:10	66.6	67.9	63.8	64.8	61.9	70	N
13-Nov-12	13:50	63.3	65.7	60.0	64.8	63.3	70	N
19-Nov-12	14:10	67.0	69.1	63.4	64.8	63.0	70	N
30-Nov-12	11:05	62.6	64.2	60.4	64.8	62.6	70	N

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
1-Nov-12	10:30	65.1	66.2	63.8	67.4	65.1	75	N
7-Nov-12	10:15	67.0	68.0	65.2	67.4	67.0	75	N
13-Nov-12	14:10	63.5	65.5	61.0	67.4	63.5	75	N
19-Nov-12	13:30	64.9	66.1	63.3	67.4	64.9	75	N
30-Nov-12	10:15	65.1	66.3	58.4	67.4	65.1	75	N

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
1-Nov-12	14:00	64.5	65.8	62.8	65.2	64.5	75	N
7-Nov-12	10:30	64.0	66.0	62.6	65.2	64.0	75	N
13-Nov-12	11:15	65.8	67.0	64.0	65.2	56.9	75	N
19-Nov-12	15:10	66.1	67.6	63.8	65.2	58.8	75	N
30-Nov-12	10:15	63.4	66.5	61.2	65.2	63.4	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
1-Nov-12	13:10	66.8	67.4	66.0	64.5	62.9	70	N
7-Nov-12	14:00	63.8	65.4	61.6	64.5	63.8	70	N
13-Nov-12	13:10	61.2	63.4	60.0	64.5	61.2	70	N
19-Nov-12	10:50	57.9	60.3	54.0	64.5	57.9	70	N
30-Nov-12	13:00	63.9	66.4	60.6	64.5	63.9	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
1-Nov-12	9:55	58.6	59.8	56.5	61.5	58.6	75	N
7-Nov-12	13:13	65.3	67.2	63.0	61.5	63.0	75	N
13-Nov-12	11:00	63.3	64.7	55.5	61.5	58.6	75	N
19-Nov-12	15:50	57.2	59.6	50.9	61.5	57.2	75	N
30-Nov-12	11:40	64.0	67.6	61.2	61.5	60.4	75	N

Remarks

* +3dB(A) Façade effect correction included

- Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.

** Construction noise level is only calculated when Measured noise level (Leq) > Impact noise level.

If Measured noise level < Impact noise level, Corrected noise level = Measured noise level