

Location : NM1A (168 Shek Kwu Lung Village G/F - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-Dec-12	15:20	63.8	65.5	60.5	64.2	63.8	75	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
6-Dec-12	14:37	67.8	69.5	65.0	68.1	67.8	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-Dec-12	13:03	63.2	65.5	60.1	64.8	63.2	70	N

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-Dec-12	13:52	65.1	66.7	61.6	67.4	65.1	75	N

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-Dec-12	13:10	67.3	69.0	63.5	65.2	63.1	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
6-Dec-12	11:20	62.2	63.5	59.5	64.5	62.2	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-Dec-12	13:53	62.5	64.0	58.5	61.5	55.6	75	N

Remarks

\* +3dB(A) Façade effect correction included

# - Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.

\*\* Construction noise level is only calculated when Measured noise level (Leq) > Impact noise level.

If Measured noise level < Impact noise level, Corrected noise level = Measured noise level