

Location : NM1A (168 Shek Kwu Lung Village G/F - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
2-Jan-13	13:50	64.0	67.4	61.2	64.2	64.0	75	N
8-Jan-13	10:45	63.8	65.2	61.6	64.2	63.8	75	N
14-Jan-13	11:30	63.8	65.5	61.5	64.2	63.8	75	N
25-Jan-13	10:45	63.5	65.0	60.5	64.2	63.5	75	N
31-Jan-13	10:46	63.9	65.5	61.7	64.2	63.9	75	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
2-Jan-13	13:05	63.6	67.0	60.3	68.1	63.6	75	N
8-Jan-13	11:29	67.3	69.1	65.7	68.1	67.3	75	N
14-Jan-13	13:15	67.6	69.5	65.0	68.1	67.6	75	N
25-Jan-13	13:08	66.3	68.3	61.6	68.1	66.3	75	N
31-Jan-13	11:27	67.2	69.1	64.6	68.1	67.2	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
2-Jan-13	10:30	61.2	63.1	58.6	64.8	61.2	70	N
8-Jan-13	10:43	65.6	68.1	63.7	64.8	57.9	70	N
14-Jan-13	10:59	63.4	65.6	60.3	64.8	63.4	70	N
25-Jan-13	10:53	65.6	67.3	61.8	64.8	57.9	70	N
31-Jan-13	13:11	65.2	67.5	63.5	64.8	54.6	70	N

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
2-Jan-13	11:15	59.8	60.9	58.1	67.4	59.8	75	N
8-Jan-13	9:55	64.0	66.1	62.3	67.4	64.0	75	N
14-Jan-13	10:13	65.2	66.8	63.2	67.4	65.2	75	N
25-Jan-13	10:05	67.2	69.1	63.7	67.4	67.2	75	N
31-Jan-13	14:03	66.5	68.5	63.0	67.4	66.5	75	N

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
2-Jan-13	13:45	63.0	65.9	61.2	65.2	63.0	75	N
8-Jan-13	14:27	63.8	65.0	62.0	65.2	63.8	75	N
14-Jan-13	13:05	66.1	67.6	63.9	65.2	58.8	75	N
25-Jan-13	13:03	66.7	68.0	63.5	65.2	61.4	75	N
31-Jan-13	13:23	65.8	67.1	63.9	65.2	56.9	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
2-Jan-13	14:40	64.2	67.9	61.6	64.5	64.2	70	N
8-Jan-13	13:40	61.9	63.5	59.5	64.5	61.9	70	N
14-Jan-13	13:55	61.8	64.1	58.7	64.5	61.8	70	N
25-Jan-13	13:50	65.0	67.2	59.9	64.5	55.4	70	N
31-Jan-13	14:05	66.3	68.1	63.2	64.5	61.6	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)  
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
2-Jan-13	13:10	63.3	68.4	60.6	61.5	58.6	75	N
8-Jan-13	13:32	63.3	65.2	61.0	61.5	58.6	75	N
14-Jan-13	10:47	63.2	64.5	60.5	61.5	58.3	75	N
25-Jan-13	14:05	63.7	65.5	61.0	61.5	59.7	75	N
31-Jan-13	15:00	63.0	65.0	60.0	61.5	57.7	75	N

#### Remarks

\* +3dB(A) Façade effect correction included

# - Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.

\*\* Construction noise level is only calculated when Measured noise level (Leq) > Impact noise level.

If Measured noise level < Impact noise level, Corrected noise level = Measured noise level