Location: NM1A (168 Shek Kwu Lung Village G/F - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

		Mea	sured Noise Le	vel for 30-min, d	IB(A)	Baseline	Corrected	Limit Level,	Exceedance
	Date	Start Time	Leq	L10	L90	Noise Level,	Construction	dB(A)	(Y/N)
3	31-Jan-13	10:46	63.9	65.5	61.7	64.2	63.9	75	N

Location: NM2 (38 Ha Wun Yiu G/F - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Mea	sured Noise Le	vel for 30-min, d	IB(A)	Baseline	Corrected	Limit Level,	Exceedance
Date	Start Time	Leq*	L10*	L90*	Noise Level,	Construction	dB(A)	(Y/N)
31-Jan-13	11:27	67.2	69.1	64.6	68.1	67.2	75	N

Location: NM3 (Wong Shiu Chi Middle School Rooftop - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Mea	sured Noise Le	vel for 30-min, d	B(A)	Baseline	Corrected	Limit Level,	Exceedance
Date	Start Time	Leq	L10	L90	Noise Level,	Construction	dB(A)#	(Y/N)
31-Jan-13	13:11	65.2	67.5	63.5	64.8	54.6	70	N

Location: NM4 (Uptown Plaza Block 4 Rooftop - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Mea	sured Noise Le	vel for 30-min, d	IB(A)	Baseline	Corrected	Limit Level,	Exceedance
Date	Start Time	Leq	L10	L90	Noise Level,	Construction	dB(A)	(Y/N)
31-Jan-13	14:03	66.5	68.5	63.0	67.4	66.5	75	N

Location: NM5 (The Paragon Clubhouse Rooftop - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

I		Mea	sured Noise Lev	vel for 30-min, d	B(A)	Baseline	Corrected	Limit Level,	Exceedance
	Date	Start Time	Leq	L10	L90	Noise Level,	Construction	dB(A)	(Y/N)
	31-Jan-13	13:23	65.8	67.1	63.9	65.2	56.9	75	N

Location: NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field) Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

I		Mea	sured Noise Le	vel for 30-min, d	IB(A)	Baseline	Corrected	Limit Level,	Exceedance
	Date	Start Time	Leq*	L10*	L90*	Noise Level,	Construction	dB(A)#	(Y/N)
	25-Jan-13	13:50	65.0	67.2	59.9	64.5	55.4	70	N

Location: NM7 (Riverain Bayside Switch Room Rooftop - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Mea	sured Noise Lev	el for 30-min, d	IB(A)	Baseline	Corrected	Limit Level,	Exceedance
Date	Start Time	Leq	L10	L90	Noise Level,	Construction	dB(A)	(Y/N)
25-Jan-13	14:05	63.7	65.5	61.0	61.5	59.7	75	N

Remarks

- * +3dB(A) Façade effect correction included
- # Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.
- ** Construction noise level is only calculated when Measured noise level (Leq) > Impact noise level.

 If Measured noise level < Impact noise level, Corrected noise level = Measured noise level