

Location : NM1A (168 Shek Kwu Lung Village G/F - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-Feb-13	10:52	62.8	64.5	59.5	64.2	62.8	75	N
15-Feb-13	10:40	62.5	64.5	59.0	64.2	62.5	75	N
21-Feb-13	10:47	65.7	67.5	62.5	64.2	75.0	75	N
27-Feb-13	13:10	63.2	64.5	61.0	64.2	63.2	75	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
6-Feb-13	13:15	66.5	68.0	65.0	68.1	66.5	75	N
15-Feb-13	14:02	67.9	69.5	65.5	68.1	67.9	75	N
21-Feb-13	11:13	67.2	69.0	65.0	68.1	67.2	75	N
27-Feb-13	11:10	62.5	63.5	61.0	68.1	62.5	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-Feb-13	11:07	64.7	67.0	59.8	64.8	64.7	70	N
15-Feb-13	11:09	66.7	68.5	63.9	64.8	70.0	70	N
21-Feb-13	11:07	67.1	69.4	63.3	64.8	70.0	70	N
27-Feb-13	10:35	56.1	57.7	53.5	64.8	56.1	70	N

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-Feb-13	10:13	65.1	66.7	63.3	67.4	65.1	75	N
15-Feb-13	10:17	63.2	64.9	60.7	67.4	63.2	75	N
21-Feb-13	10:15	65.2	67.0	63.1	67.4	65.2	75	N
27-Feb-13	9:50	59.0	63.5	51.6	67.4	59.0	75	N

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-Feb-13	13:10	67.3	68.8	65.1	65.2	75.0	75	N
15-Feb-13	13:09	66.0	68.1	63.2	65.2	75.0	75	N
21-Feb-13	13:20	68.1	69.4	66.5	65.2	75.0	75	N
27-Feb-13	13:00	57.9	60.8	54.3	65.2	57.9	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
6-Feb-13	11:30	65.3	67.0	63.5	64.5	70.0	70	N
15-Feb-13	13:18	61.2	63.0	58.0	64.5	61.2	70	N
21-Feb-13	14:19	63.2	65.0	59.5	64.5	63.2	70	N
27-Feb-13	11:30	64.3	66.9	54.0	64.5	64.3	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
6-Feb-13	14:02	62.6	64.0	60.0	61.5	75.0	75	N
15-Feb-13	11:22	62.1	63.5	59.0	61.5	75.0	75	N
21-Feb-13	13:33	62.2	64.0	59.5	61.5	75.0	75	N
27-Feb-13	10:25	58.0	59.5	53.5	61.5	58.0	75	N

Remarks

* +3dB(A) Façade effect correction included

- Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.

** Construction noise level is only calculated when Measured noise level (Leq) > Impact noise level.

If Measured noise level < Impact noise level, Corrected noise level = Measured noise level