

Location : NM1A (168 Shek Kwu Lung Village G/F - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
27-Feb-13	13:10	63.2	64.5	61.0	64.2	63.2	75	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
27-Feb-13	11:10	62.5	63.5	61.0	68.1	62.5	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
27-Feb-13	10:35	56.1	57.7	53.5	64.8	56.1	70	N

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
27-Feb-13	9:50	59.0	63.5	51.6	67.4	59.0	75	N

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
27-Feb-13	13:00	57.9	60.8	54.3	65.2	57.9	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
27-Feb-13	11:30	64.3	66.9	54.0	64.5	64.3	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
27-Feb-13	10:25	58.0	59.5	53.5	61.5	58.0	75	N

Remarks

\* +3dB(A) Façade effect correction included

# - Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.

\*\* Construction noise level is only calculated when Measured noise level (Leq) > Impact noise level.

If Measured noise level < Impact noise level, Corrected noise level = Measured noise level