

Location : NM1A (168 Shek Kwu Lung Village G/F - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
15-Apr-13	11:23	63.3	65.0	60.5	64.2	63.3	75	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
15-Apr-13	13:30	67.9	69.5	65.0	68.1	67.9	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
15-Apr-13	11:28	62.7	64.3	60.2	64.8	62.7	70	N

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
15-Apr-13	10:45	63.5	65.2	60.7	67.4	63.5	75	N

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
15-Apr-13	14:30	66.8	68.0	65.0	65.2	61.7	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
15-Apr-13	14:13	63.5	65.1	61.1	64.5	63.5	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
15-Apr-13	13:43	61.6	63.5	58.0	61.5	45.2	75	N

Remarks

\* +3dB(A) Façade effect correction included

# - Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.

\*\* Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level.

If Measured noise level < Baseline noise level, Corrected noise level = Measured noise level