

Location : NM1A (168 Shek Kwu Lung Village G/F- Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
8-May-13	10:43	63.3	66.5	57.5	64.2	63.3	75	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
8-May-13	11:30	67.4	69.0	65.0	68.1	67.4	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
8-May-13	10:32	63.8	65.3	60.7	64.8	63.8	70	N

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
8-May-13	11:26	63.3	65.1	60.5	67.4	63.3	75	N

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
8-May-13	14:20	66.5	67.9	65.0	65.2	60.6	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
8-May-13	13:15	61.3	63.1	57.9	64.5	61.3	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
8-May-13	13:31	61.7	63.0	58.0	61.5	48.2	75	N

Remarks

* +3dB(A) Façade effect correction included

- Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.

** Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level.

If Measured noise level < Baseline noise level, Corrected noise level = Measured noise level