

Location : NM1A (168 Shek Kwu Lung Village G/F - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
4-Jul-13	10:48	61.5	63.0	58.0	64.2	61.5	75	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
4-Jul-13	11:29	68.5	70.0	65.5	68.1	75.0	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
4-Jul-13	11:16	65.4	67.1	63.3	64.8	70.0	70	Y

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
4-Jul-13	10:23	63.9	65.3	61.7	67.4	63.9	75	N

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
4-Jul-13	13:50	67.3	69.0	65.0	65.2	75.0	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
4-Jul-13	13:48	61.8	63.4	58.7	64.5	61.8	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)
Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level,	Corrected Construction	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
4-Jul-13	14:32	60.4	62.0	57.5	61.5	60.4	75	N

Remarks

* +3dB(A) Façade effect correction included

- Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.

** Construction noise level is only calculated when Measured noise level (Leq) > Impact noise level.

If Measured noise level < Impact noise level, Corrected noise level = Measured noise level