

Location : NM1A (168 Shek Kwu Lung Village G/F- Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
14-Aug-13	15:05	59.8	61.0	56.5	64.2	59.8	75	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
14-Aug-13	15:15	61.5	62.8	60.0	68.1	61.5	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
14-Aug-13	14:50	61.9	63.0	60.5	64.8	61.9	70	N

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
14-Aug-13	15:35	62.3	64.0	61.0	67.4	62.3	75	N

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
14-Aug-13	16:00	60.0	61.3	58.1	65.2	60.0	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
14-Aug-13	16:00	61.8	63.0	60.5	64.5	61.8	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
14-Aug-13	14:35	57.7	58.5	54.5	61.5	57.7	75	N

Remarks

* +3dB(A) Façade effect correction included

- Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.

** Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level.

If Measured noise level < Baseline noise level, Corrected noise level = Measured noise level