

Location : NM1A (168 Shek Kwu Lung Village G/F- Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

| Date      | Measured Noise Level for 30-min, dB(A) |      |      |      | Baseline Noise Level, dB(A) | Corrected Construction Noise Level, dB(A) ** | Limit Level, dB(A) | Exceedance (Y/N) |
|-----------|--|------|------|------|-----------------------------|--|--------------------|------------------|
|           | Start Time                             | Leq  | L10  | L90  |                             |  |                    |                  |
| 6-Sep-13  | 15:15                                  | 60.4 | 62.5 | 59.0 | 64.2                        | 60.4   | 75                 | N                |
| 12-Sep-13 | 9:40                                   | 57.7 | 58.9 | 56.3 | 64.2                        | 57.7   | 75                 | N                |
| 18-Sep-13 | 11:22                                  | 64.1 | 66.5 | 62.6 | 64.2                        | 64.1   | 75                 | N                |
| 23-Sep-13 | 11:07                                  | 63.5 | 65.0 | 62.0 | 64.2                        | 63.5   | 75                 | N                |
| 27-Sep-13 | 11:10                                  | 60.6 | 61.5 | 56.5 | 64.2                        | 60.6   | 75                 | N                |

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

| Date      | Measured Noise Level for 30-min, dB(A) |      |      |      | Baseline Noise Level, dB(A)* | Corrected Construction Noise Level, dB(A) ** | Limit Level, dB(A) | Exceedance (Y/N) |
|-----------|--|------|------|------|------------------------------|--|--------------------|------------------|
|           | Start Time                             | Leq* | L10* | L90* |                              |  |                    |                  |
| 6-Sep-13  | 13:45                                  | 64.0 | 65.5 | 61.5 | 68.1                         | 64.0   | 75                 | N                |
| 12-Sep-13 | 11:00                                  | 61.9 | 63.0 | 59.4 | 68.1                         | 61.9   | 75                 | N                |
| 18-Sep-13 | 16:22                                  | 62.4 | 63.8 | 60.1 | 68.1                         | 62.4   | 75                 | N                |
| 23-Sep-13 | 10:54                                  | 65.9 | 67.7 | 63.0 | 68.1                         | 65.9   | 75                 | N                |
| 27-Sep-13 | 13:00                                  | 62.4 | 64.0 | 60.5 | 68.1                         | 62.4   | 75                 | N                |

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

| Date      | Measured Noise Level for 30-min, dB(A) |      |      |      | Baseline Noise Level, dB(A) | Corrected Construction Noise Level, dB(A) ** | Limit Level, dB(A)# | Exceedance (Y/N) |
|-----------|--|------|------|------|-----------------------------|--|---------------------|------------------|
|           | Start Time                             | Leq  | L10  | L90  |                             |  |                     |                  |
| 6-Sep-13  | 11:30                                  | 63.3 | 64.0 | 61.0 | 64.8                        | 63.3   | 70                  | N                |
| 12-Sep-13 | 13:00                                  | 60.7 | 62.4 | 57.0 | 64.8                        | 60.7   | 70                  | N                |
| 18-Sep-13 | 13:52                                  | 65.1 | 66.2 | 63.5 | 64.8                        | 0.0  | 70                  | N                |
| 23-Sep-13 | 13:03                                  | 64.3 | 66.5 | 61.5 | 64.8                        | 64.3   | 70                  | N                |
| 27-Sep-13 | 10:45                                  | 63.1 | 64.8 | 61.1 | 64.8                        | 63.1   | 70                  | N                |

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

| Date      | Measured Noise Level for 30-min, dB(A) |      |      |      | Baseline Noise Level, dB(A) | Corrected Construction Noise Level, dB(A) ** | Limit Level, dB(A) | Exceedance (Y/N) |
|-----------|--|------|------|------|-----------------------------|--|--------------------|------------------|
|           | Start Time                             | Leq  | L10  | L90  |                             |  |                    |                  |
| 6-Sep-13  | 10:36                                  | 62.0 | 63.5 | 60.0 | 67.4                        | 62.0   | 75                 | N                |
| 12-Sep-13 | 11:30                                  | 62.3 | 64.8 | 59.6 | 67.4                        | 62.3   | 75                 | N                |
| 18-Sep-13 | 13:05                                  | 65.8 | 67.2 | 64.0 | 67.4                        | 65.8   | 75                 | N                |
| 23-Sep-13 | 13:10                                  | 65.7 | 67.2 | 62.5 | 67.4                        | 65.7   | 75                 | N                |
| 27-Sep-13 | 9:45                                   | 60.4 | 63.3 | 58.9 | 67.4                        | 60.4   | 75                 | N                |

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

| Date      | Measured Noise Level for 30-min, dB(A) |      |      |      | Baseline Noise Level, dB(A) | Corrected Construction Noise Level, dB(A) ** | Limit Level, dB(A) | Exceedance (Y/N) |
|-----------|--|------|------|------|-----------------------------|--|--------------------|------------------|
|           | Start Time                             | Leq  | L10  | L90  |                             |  |                    |                  |
| 6-Sep-13  | 14:31                                  | 60.4 | 62.5 | 58.5 | 65.2                        | 60.4   | 75                 | N                |
| 12-Sep-13 | 13:10                                  | 58.3 | 60.2 | 56.2 | 65.2                        | 58.3   | 75                 | N                |
| 18-Sep-13 | 16:10                                  | 56.7 | 58.9 | 54.3 | 65.2                        | 56.7   | 75                 | N                |
| 23-Sep-13 | 13:45                                  | 66.7 | 68.5 | 63.5 | 65.2                        | 0.0  | 75                 | N                |
| 27-Sep-13 | 13:30                                  | 62.9 | 64.1 | 59.3 | 65.2                        | 62.9   | 75                 | N                |

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

| Date      | Measured Noise Level for 30-min, dB(A) |      |      |      | Baseline Noise Level, dB(A)* | Corrected Construction Noise Level, dB(A) ** | Limit Level, dB(A)# | Exceedance (Y/N) |
|-----------|--|------|------|------|------------------------------|--|---------------------|------------------|
|           | Start Time                             | Leq* | L10* | L90* |                              |  |                     |                  |
| 6-Sep-13  | 13:02                                  | 61.1 | 63.0 | 59.5 | 64.5                         | 61.1   | 70                  | N                |
| 12-Sep-13 | 13:40                                  | 57.2 | 58.5 | 55.6 | 64.5                         | 57.2   | 70                  | N                |
| 18-Sep-13 | 14:35                                  | 56.5 | 58.1 | 54.2 | 64.5                         | 56.5   | 70                  | N                |
| 23-Sep-13 | 13:55                                  | 60.7 | 62.2 | 58.1 | 64.5                         | 60.7   | 70                  | N                |
| 27-Sep-13 | 14:00                                  | 62.6 | 63.5 | 61.5 | 64.5                         | 62.6   | 70                  | N                |

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)  
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

| Date      | Measured Noise Level for 30-min, dB(A) |      |      |      | Baseline Noise Level, dB(A) | Corrected Construction Noise Level, dB(A) ** | Limit Level, dB(A) | Exceedance (Y/N) |
|-----------|--|------|------|------|-----------------------------|--|--------------------|------------------|
|           | Start Time                             | Leq  | L10  | L90  |                             |  |                    |                  |
| 6-Sep-13  | 9:48                                   | 59.9 | 62.0 | 57.0 | 61.5                        | 59.9   | 75                 | N                |
| 12-Sep-13 | 10:20                                  | 57.1 | 58.5 | 55.0 | 61.5                        | 57.1   | 75                 | N                |
| 18-Sep-13 | 13:17                                  | 58.3 | 61.2 | 55.8 | 61.5                        | 58.3   | 75                 | N                |
| 23-Sep-13 | 14:48                                  | 62.5 | 64.3 | 60.5 | 61.5                        | 0.0  | 75                 | N                |
| 27-Sep-13 | 10:20                                  | 58.0 | 59.5 | 56.5 | 61.5                        | 58.0   | 75                 | N                |

Remarks

\* +3dB(A) Façade effect correction included

# - Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.

\*\* Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level.

If Measured noise level < Baseline noise level, Corrected noise level = Measured noise level