

Location : NM1A (168 Shek Kwu Lung Village G/F- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
10-Jan-14	10:40	60.5	62.0	56.5	64.2	60.5	75	N
16-Jan-14	10:44	60.3	62.1	56.5	64.2	60.3	75	N
22-Jan-14	11:05	62.1	63.9	59.0	64.2	62.1	75	N
27-Jan-14	10:20	63.3	64.5	60.0	64.2	63.3	75	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
10-Jan-14	10:20	65.4	66.5	64.0	68.1	65.4	75	N
16-Jan-14	13:28	67.3	69.4	65.0	68.1	67.3	75	N
22-Jan-14	10:30	64.1	65.5	62.4	68.1	64.1	75	N
27-Jan-14	10:40	64.7	66.0	63.0	68.1	64.7	75	N

\* +3dB(A) Façade effect correction included

\*\* Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level.

If Measured noise level < Baseline noise level, Corrected noise level = Measured noise level

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A) <sup>#</sup>	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
10-Jan-14	13:20	61.4	63.5	60.0	64.8	61.4	65	N
16-Jan-14	10:16	63.7	65.5	61.5	64.8	63.7	65	N
22-Jan-14	13:15	62.4	63.7	60.5	64.8	62.4	70	N
27-Jan-14	13:10	62.7	64.0	60.0	64.8	62.7	70	N

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
10-Jan-14	13:05	62.0	64.0	60.5	67.4	62.0	75	N
16-Jan-14	10:16	66.1	68.0	63.5	67.4	66.1	75	N
22-Jan-14	13:05	63.0	64.4	60.0	67.4	63.0	75	N
27-Jan-14	13:00	63.3	64.5	60.5	67.4	63.3	75	N

# - Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.

\*\* Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level.

If Measured noise level < Baseline noise level, Corrected noise level = Measured noise level

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
10-Jan-14	11:30	64.1	65.5	61.5	65.2	64.1	75	N
16-Jan-14	13:15	67.7	69.4	65.1	65.2	0.0	75	N
22-Jan-14	14:00	63.6	65.0	60.1	65.2	63.6	75	N
27-Jan-14	11:00	65.5	66.5	62.0	65.2	0.0	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
10-Jan-14	11:10	63.4	64.5	62.5	64.5	63.4	70	N
16-Jan-14	11:30	62.2	63.9	60.1	64.5	62.2	70	N
22-Jan-14	11:20	63.2	64.4	62.0	64.5	63.2	70	N
27-Jan-14	11:30	62.0	64.5	62.0	64.5	62.0	70	N

Remarks

\* +3dB(A) Façade effect correction included

# - Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.

\*\* Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level.

If Measured noise level < Baseline noise level, Corrected noise level = Measured noise level

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
10-Jan-14	9:50	58.6	60.0	55.5	61.5	58.6	75	N
16-Jan-14	14:15	58.8	60.5	56.2	61.5	58.8	75	N
22-Jan-14	9:50	57.7	59.0	56.0	61.5	57.7	75	N
27-Jan-14	9:45	58.1	59.5	56.5	61.5	58.1	75	N

Remarks

\*\* Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level.

If Measured noise level < Baseline noise level, Corrected noise level = Measured noise level