

Location : NM1A (168 Shek Kwu Lung Village G/F- Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
8-May-14	13:43	66.7	68.1	64.2	64.2	63.1	75	N
13-May-14	13:49	65.7	68.2	63.5	64.2	60.4	75	N
19-May-14	16:16	63.3	65.0	61.1	64.2	63.3	75	N
30-May-14	10:20	61.1	58.3	62.5	64.2	61.1	75	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
8-May-14	10:58	68.3	69.7	66.4	68.1	54.8	75	N
13-May-14	10:50	67.3	69.1	65.4	68.1	67.3	75	N
19-May-14	14:32	69.3	71.0	66.2	68.1	63.1	75	N
30-May-14	11:30	68.3	70.2	65.7	68.1	54.8	75	N

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
8-May-14	10:40	67.5	70.2	65.1	64.8	64.2	70	N
13-May-14	10:42	66.4	68.7	64.3	64.8	61.3	70	N
19-May-14	13:06	66.3	67.9	63.8	64.8	61.0	70	N
30-May-14	15:20	66.9	68.3	63.8	64.8	62.7	70	N

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
8-May-14	9:57	66.9	68.7	63.6	67.4	66.9	75	N
13-May-14	9:45	65.9	68.4	63.8	67.4	65.9	75	N
19-May-14	13:48	65.2	66.8	63.1	67.4	65.2	75	N
30-May-14	15:05	65.7	67.5	63.5	67.4	65.7	75	N

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
8-May-14	13:39	64.3	66.5	62.7	65.2	64.3	75	N
13-May-14	13:40	62.9	64.8	60.1	65.2	62.9	75	N
19-May-14	15:30	67.4	69.0	65.0	65.2	63.4	75	N
30-May-14	10:35	67.2	69.0	64.5	65.2	62.9	75	N

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)#	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*				
8-May-14	11:28	63.7	66.2	61.5	64.5	63.7	70	N
13-May-14	11:29	63.1	65.7	61.7	64.5	63.1	70	N
19-May-14	14:40	62.3	64.0	60.0	64.5	62.3	70	N
30-May-14	14:00	60.7	62.0	57.0	64.5	60.7	70	N

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Baseline Noise Level, dB(A)	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq	L10	L90				
8-May-14	10:11	65.6	67.1	63.6	61.5	63.5	75	N
13-May-14	9:52	66.3	69.1	64.5	61.5	64.6	75	N
19-May-14	11:18	61.7	63.5	57.5	61.5	48.2	75	N
30-May-14	9:35	63.1	64.5	60.0	61.5	58.0	75	N

Remarks

- * +3dB(A) Façade effect correction included
- # - Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.
- ** Construction noise level is only calculated when Measured noise level (Leq) > Baseline noise level.
 If Measured noise level < Baseline noise level, Corrected noise level = Measured noise level