

Appendix I Impact Daytime Construction Noise Monitoring Results

Location : NM1A (168 Shek Kwu Lung Village G/F - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)			Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)†	Exceedance (Y/N)
	Start Time‡	Leq	L10				
7-Aug-14	14:40	64.1	66.2	62.7	64.2	75	N

Location : NM2 (38 Ha Wun Yiu G/F - Free Field)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)			Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)†	Exceedance (Y/N)
	Start Time‡	Leq	L10				
Construction Phase EM&A Programme for Contract 1 of the Project was completed on 15 July 2014. No monitoring has been carried out beyond 15 July 2014.							

Location : NM3 (Wong Shiu Chi Middle School Rooftop - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)			Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)†	Exceedance (Y/N)
	Start Time‡	Leq	L10				
Construction Phase EM&A Programme for Contract 1 of the Project was completed on 15 July 2014. No monitoring has been carried out beyond 15 July 2014.							

Location : NM4 (Uptown Plaza Block 4 Rooftop - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)			Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)†	Exceedance (Y/N)
	Start Time‡	Leq	L10				
Construction Phase EM&A Programme for Contract 1 of the Project was completed on 15 July 2014. No monitoring has been carried out beyond 15 July 2014.							

Location : NM5 (The Paragon Clubhouse Rooftop - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)			Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)†	Exceedance (Y/N)
	Start Time‡	Leq	L10				
Construction Phase EM&A Programme for Contract 1 of the Project was completed on 15 July 2014. No monitoring has been carried out beyond 15 July 2014.							

Location : NM6 (PLK Tin Ka Ping Primary School near the entrance - Free Field)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)			Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)†	Exceedance (Y/N)
	Start Time‡	Leq	L10				
Construction Phase EM&A Programme for Contract 1 of the Project was completed on 15 July 2014. No monitoring has been carried out beyond 15 July 2014.							

Location : NM7 (Riverain Bayside Switch Room Rooftop - Façade)
 Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)			Baseline Noise Level, dB(A)*	Corrected Construction Noise Level, dB(A) **	Limit Level, dB(A)†	Exceedance (Y/N)
	Start Time‡	Leq	L10				
Construction Phase EM&A Programme for Contract 1 of the Project was completed on 15 July 2014. No monitoring has been carried out beyond 15 July 2014.							