

## Impact Daytime Construction Noise Monitoring Results

### Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*		
3-Aug-15	13:25	68.5	69.5	66.0	75	N
14-Aug-15	10:00	70.2	73.6	68.5	75	N
18-Aug-15	14:00	69.6	73.2	66.8	75	N
28-Aug-15	14:00	70.2	73.6	68.1	75	N

### Location : M3 (Fanling Government Secondary School- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)^	Exceedance (Y/N)
	Start Time	Leq	L10	L90		
3-Aug-15	13:00	62.1	63.5	60.0	70	N
14-Aug-15	10:50	64.1	67.3	62.0	70	N
18-Aug-15	13:00	64.2	66.8	61.6	70	N
28-Aug-15	14:10	64.1	67.3	62.6	70	N

\* +3dB(A) Façade effect correction included

^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.