## **Impact Daytime Construction Noise Monitoring Results**

Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

|          | Meas       | sured Noise Lev | Limit Level, | Exceedance |       |       |
|----------|------------|-----------------|--------------|------------|-------|-------|
| Date     | Start Time | Leq*            | L10*         | L90*       | dB(A) | (Y/N) |
| 9-Nov-15 | 13:15      | 69.6            | 72.3         | 67.0       | 75    | N     |

**Location : M3 (Fanling Government Secondary School- Façade)**Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

|          | Meas       | ured Noise Lev | Limit Level, | Exceedance |        |       |
|----------|------------|----------------|--------------|------------|--------|-------|
| Date     | Start Time | Leq            | L10          | L90        | dB(A)^ | (Y/N) |
| 9-Nov-15 | 14:00      | 64.4           | 67.3         | 61.2       | 65     | N     |

<sup>\* +3</sup>dB(A) Façade effect correction included ^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination per