

Impact Daytime Construction Noise Monitoring Results

Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*		
6-Jan-16	14:06	71.0	73.1	69.5	75	N
12-Jan-16	11:20	69.8	71.5	67.5	75	N
18-Jan-16	10:50	69.0	71.5	66.5	75	N
29-Jan-16	11:10	68.6	71.2	63.4	75	N

Location : M3 (Fanling Government Secondary School- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)^	Exceedance (Y/N)
	Start Time	Leq	L10	L90		
6-Jan-16	14:50	69.8	71.6	65.9	70	N
12-Jan-16	10:22	65.8	67.0	63.0	70	N
18-Jan-16	10:00	63.5	65.0	60.0	70	N
29-Jan-16	10:30	64.0	67.9	60.5	70	N

* +3dB(A) Façade effect correction included

^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period