

## Impact Daytime Construction Noise Monitoring Results

### Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*		
6-Jun-16	11:45	66.8	69.5	64.0	75	N
17-Jun-16	13:10	69.8	72.3	64.2	75	N
23-Jun-16	15:19	69.8	71.9	67.2	75	N
29-Jun-16	15:08	68.9	70.5	67.0	75	N

### Location : M3 (Fanling Government Secondary School- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)^	Exceedance (Y/N)
	Start Time	Leq	L10	L90		
6-Jun-16	11:00	60.6	62.0	58.0	70	N
17-Jun-16	14:00	64.1	67.3	59.2	65	N
23-Jun-16	16:17	64.8	69.4	60.2	65	N
29-Jun-16	16:00	64.1	65.5	63.0	70	N

\* +3dB(A) Façade effect correction included

^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period