

Impact Daytime Construction Noise Monitoring Results

Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*		
5-Sep-16	10:03	68.9	70.0	65.9	75	N
15-Sep-16	14:30	69.9	71.5	63.0	75	N
21-Sep-16	13:00	69.7	71.1	66.8	75	N
27-Sep-16	14:20	68.8	70.5	66.0	75	N

Location : M3 (Fanling Government Secondary School- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)^	Exceedance (Y/N)
	Start Time	Leq	L10	L90		
5-Sep-16	10:49	65.6	66.2	62.1	70	N
15-Sep-16	13:30	65.0	67.5	61.0	70	N
21-Sep-16	13:50	64.6	66.1	62.0	70	N
27-Sep-16	14:00	62.5	63.5	60.0	70	N

* +3dB(A) Façade effect correction included

^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period