

## Appendix I Impact Daytime Construction Noise Monitoring Results

### Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*		
4-May-17	13:10	69.2	73.6	64.0	75	N
10-May-17	11:15	69.7	72.9	63.5	75	N
16-May-17	14:05	69.7	71.3	67.2	75	N
22-May-17	13:10	67.7	69.0	64.5	75	N

### Location : M3 (Fanling Government Secondary School- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)^	Exceedance (Y/N)
	Start Time	Leq	L10	L90		
4-May-17	14:05	64.2	67.8	60.6	65	N
10-May-17	11:30	64.2	67.2	59.6	70	N
16-May-17	13:10	65.1	67.3	32.2	70	N
22-May-17	11:35	60.1	61.0	56.0	70	N

\* +3dB(A) Façade effect correction included

^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.