

Appendix I Impact Daytime Construction Noise Monitoring Results

Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*		
4-Oct-17	10:05	68.5	70.0	64.5	75	N
9-Oct-17	10:10	70.1	74.2	63.2	75	N
19-Oct-17	15:00	67.9	69.5	65.2	75	N
25-Oct-17	15:20	67.3	68.9	65.1	75	N
30-Oct-17	11:09	70.9	72.3	67.2	75	N

Location : M3 (Fanling Government Secondary School- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)^	Exceedance (Y/N)
	Start Time	Leq	L10	L90		
4-Oct-17	9:45	60.0	61.0	56.5	70	N
9-Oct-17	10:30	64.1	66.9	61.0	70	N
19-Oct-17	13:40	63.7	65.2	61.3	70	N
25-Oct-17	14:15	63.3	65.1	60.1	70	N
30-Oct-17	9:59	67.5	69.2	65.3	70	N

* +3dB(A) Façade effect correction included

^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.