

Impact Daytime Construction Noise Monitoring Results

Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*		
2-Jan-18	10:30	68.4	70.0	66.5	75	N
12-Jan-18	10:20	70.6	73.6	67.2	75	N
18-Jan-18	11:20	65.7	66.4	64.3	75	N
24-Jan-18	14:10	69.3	71.8	67.0	75	N
30-Jan-18	13:20	67.7	69.0	63.5	75	N

Location : M3 (Fanling Government Secondary School- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)^	Exceedance (Y/N)
	Start Time	Leq	L10	L90		
2-Jan-18	10:00	61.1	62.0	56.6	70	N
12-Jan-18	9:30	63.6	66.7	60.6	70	N
18-Jan-18	10:45	64.2	65.5	63.8	70	N
24-Jan-18	13:15	65.8	67.7	63.6	70	N
30-Jan-18	13:00	60.0	61.0	57.0	65	N

* +3dB(A) Façade effect correction included

^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.