Impact Daytime Construction Noise Monitoring Results

Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Meas	ured Noise Lev	Limit Level,	Exceedance		
Date	Start Time	Leq*	L10*	L90*	dB(A)	(Y/N)
24-Jan-18	14:10	69.3	71.8	67.0	75	N

Location : M3 (Fanling Government Secondary School- Façade)Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Meas	ured Noise Le	Limit Level,	Exceedance		
Date	Start Time	Leq	L10	L90	dB(A)^	(Y/N)
24-Jan-18	13:15	65.8	67.7	63.6	70	N

^{* +3}dB(A) Façade effect correction included

[^] Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.