## Impact Daytime Construction Noise Monitoring Results

## Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Meas	ured Noise Le	Limit Level,	Exceedance		
Date	Start Time	Leq*	L10*	L90*	dB(A)	(Y/N)
5-Feb-18	13:35	70.8	72.3	68.7	75	N

Location : M3 (Fanling Government Secondary School- Façade) Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Meas	sured Noise Le	Limit Level,	Exceedance		
Date	Start Time	Leq	L10	L90	dB(A)^	(Y/N)
5-Feb-18	14:40	67.4	69.5	65.7	70	N

\* +3dB(A) Façade effect correction included
^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.