

Impact Daytime Construction Noise Monitoring Results

Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*		
5-Nov-18	11:05	67.8	69.5	64.0	75	N
16-Nov-18	11:05	66.4	67.5	64.0	75	N
22-Nov-18	16:05	67.5	69.3	65.0	75	N
28-Nov-18	10:25	69.7	71.4	67.2	75	N

Location : M3 (Fanling Government Secondary School- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)^	Exceedance (Y/N)
	Start Time	Leq	L10	L90		
5-Nov-18	10:15	59.6	60.5	56.5	70	N
16-Nov-18	10:15	60.0	61.0	56.5	70	N
22-Nov-18	16:52	62.9	64.6	60.5	70	N
28-Nov-18	9:30	66.2	68.1	64.3	70	N

* +3dB(A) Façade effect correction included

^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.