

Impact Daytime Construction Noise Monitoring Results

Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*		
4-Dec-18	11:20	64.4	66.0	62.0	75	N
10-Dec-18	10:15	61.0	62.0	57.5	75	N
21-Dec-18	10:15	68.6	70.2	66.9	75	N
27-Dec-18	14:20	68.0	70.0	66.0	75	N

Location : M3 (Fanling Government Secondary School- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)^	Exceedance (Y/N)
	Start Time	Leq	L10	L90		
4-Dec-18	10:30	60.3	61.0	55.5	70	N
10-Dec-18	11:00	65.7	67.5	64.0	70	N
21-Dec-18	9:30	65.2	67.8	63.6	70	N
27-Dec-18	14:05	59.5	60.5	56.5	70	N

* +3dB(A) Façade effect correction included

^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.