

## Impact Daytime Construction Noise Monitoring Results

### Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*		
2-Jan-19	10:20	64.3	66.5	62.5	75	N
7-Jan-19	13:25	64.9	66.5	62.5	75	N
18-Jan-19	13:30	68.6	70.3	66.9	75	N
24-Jan-19	10:05	68.4	70.0	66.5	75	N
30-Jan-19	10:15	65.6	67.1	64.1	75	N

### Location : M3 (Fanling Government Secondary School- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)^	Exceedance (Y/N)
	Start Time	Leq	L10	L90		
2-Jan-19	10:00	59.0	60.0	53.0	70	N
7-Jan-19	13:05	60.1	61.0	56.0	65	N
18-Jan-19	14:15	64.2	66.0	62.3	70	N
24-Jan-19	11:00	64.1	65.8	62.0	70	N
30-Jan-19	10:55	64.0	65.9	62.2	65	N

\* +3dB(A) Façade effect correction included

^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.