## Impact Daytime Construction Noise Monitoring Results

## Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Meas	sured Noise Lev	Limit Level,	Exceedance		
Date	Start Time	Leq*	L10*	L90*	dB(A)	(Y/N)
18-Jan-19	13:30	68.6	70.3	66.9	75	N

## Location : M3 (Fanling Government Secondary School- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Meas	sured Noise Le	Limit Level,	Exceedance		
Date	Start Time	Leq	L10	L90	dB(A)^	(Y/N)
18-Jan-19	14:15	64.2	66.0	62.3	70	N

\* +3dB(A) Façade effect correction included
^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.