

## Impact Daytime Construction Noise Monitoring Results

### Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

| Date     | Measured Noise Level for 30-min, dB(A) |      |      |      | Limit Level, dB(A) | Exceedance (Y/N) |
|----------|--|------|------|------|--------------------|------------------|
|          | Start Time                             | Leq* | L10* | L90* |                    |                  |
| 6-Aug-19 | 10:20                                  | 66.7 | 68.0 | 64.5 | 75                 | N                |

### Location : M3 (Fanling Government Secondary School- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

| Date     | Measured Noise Level for 30-min, dB(A) |      |      |      | Limit Level, dB(A)^ | Exceedance (Y/N) |
|----------|--|------|------|------|---------------------|------------------|
|          | Start Time                             | Leq  | L10  | L90  |                     |                  |
| 6-Aug-19 | 10:00                                  | 60.0 | 61.0 | 55.0 | 70                  | N                |

\* +3dB(A) Façade effect correction included

^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.