

## Appendix I Impact Daytime Construction Noise Monitoring Results

### Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*		
6-Apr-20	13:00	64.7	66.0	62.5	75	N
15-Apr-20	11:10	68.8	70.4	68.8	75	N
21-Apr-20	13:30	66.7	67.5	64.5	75	N
29-Apr-20	15:05	68.5	69.8	66.0	75	N
	Min	64.7	66.0	62.5		
	Max	68.8	70.4	68.8		
	Average	67.5	68.8	66.1		

### Location : M3 (Fanling Government Secondary School- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)^	Exceedance (Y/N)
	Start Time	Leq	L10	L90		
6-Apr-20	11:00	60.2	61.0	55.5	70	N
15-Apr-20	10:03	65.0	66.2	62.5	70	N
21-Apr-20	14:00	60.6	61.5	56.5	70	N
29-Apr-20	13:40	63.7	65.5	60.9	70	N
	Min	60.2	61.0	55.5		
	Max	65.0	66.2	62.5		
	Average	62.8	64.1	59.8		

\* +3dB(A) Façade effect correction included

^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.