

## Appendix I Impact Daytime Construction Noise Monitoring Results

### Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*		
4-Nov-20	14:05	66.8	67.5	64.0	75	N
10-Nov-20	14:30	66.2	67.5	63.0	75	N
16-Nov-20	14:10	65.4	66.5	62.5	75	N
27-Nov-20	13:45	65.3	66.5	62.0	75	N
	Min	65.3	66.5	62.0		
	Max	66.8	67.5	64.0		
	Average	66.0	67.0	62.9		

### Location : M3 (Fanling Government Secondary School- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)^	Exceedance (Y/N)
	Start Time	Leq	L10	L90		
4-Nov-20	13:25	60.2	61.5	56.0	70	N
10-Nov-20	13:05	59.8	61.0	56.0	70	N
16-Nov-20	13:05	65.4	66.5	62.5	70	N
27-Nov-20	13:05	60.2	61.5	55.0	70	N
	Min	59.8	61.0	55.0		
	Max	65.4	66.5	62.5		
	Average	62.1	63.3	58.6		

\* +3dB(A) Façade effect correction included

^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.