

## Appendix I Impact Daytime Construction Noise Monitoring Results

### Location : M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)	Exceedance (Y/N)
	Start Time	Leq*	L10*	L90*		
5-May-21	14:05	67.1	68.5	64.5	75	N
11-May-21	13:05	68.1	69.5	65.0	75	N
17-May-21	10:50	64.7	66.5	61.0	75	N
28-May-21	11:00	66.3	67.0	63.0	75	N
	Min	64.7	66.5	61.0		
	Max	68.1	69.5	65.0		
	Average	66.7	68.0	63.6		

### Location : M3 (Fanling Government Secondary School- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

Date	Measured Noise Level for 30-min, dB(A)				Limit Level, dB(A)^	Exceedance (Y/N)
	Start Time	Leq	L10	L90		
5-May-21	15:00	63.2	64.5	61.0	70	N
11-May-21	10:55	63.6	65.0	61.5	70	N
17-May-21	10:00	60.2	61.0	57.0	70	N
28-May-21	10:00	60.1	61.0	56.0	70	N
	Min	60.1	61.0	56.0		
	Max	63.6	65.0	61.5		
	Average	62.1	63.3	59.5		

\* +3dB(A) Façade effect correction included

^ Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.