## **Impact Daytime Construction Noise Monitoring Results**

Location: M2 (West Tai Wo - Free Field)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Meas	ured Noise Lev	Limit Level,	Exceedance		
Date	Start Time	Leq*	L10*	L90*	dB(A)	(Y/N)
8-Sep-21	14:00	65.6	66.9	63.4	75	N

## Location: M3 (Fanling Government Secondary School- Façade)

Day time 07:00-19:00 hrs Normal Weekdays Impact Noise Monitoring Results

	Meas	ured Noise Lev	Limit Level,	Exceedance		
Date	Start Time	Leq	L10	L90	dB(A)^	(Y/N)
8-Sep-21	14:45	63.2	63.4	61.9	70	N

<sup>\* +3</sup>dB(A) Façade effect correction included

<sup>^</sup> Limit Level of 70dB(A) applies to education institutes while 65dB(A) applies during school examination period.